

AUG 30 1979

State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

OCT 4 1979 WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION 1/4 Section NW Section 8 Township 10N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Roger L. McKittrick

OR - Grid or Street No. Street Name ADDRESS Box 214

AND - If available subdivision name, lot & block No. POST OFFICE Ferrysville, Wisc. 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 40' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Dr. Sewage Absorption Unit 100' Seepage Pit Seepage Bed Seepage Trench

Septic Tank 75' Holding Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

9. FORMATIONS

| Kind | From (ft.) | To (ft.) |
|---------------------------|----------------|---------------|
| <u>Clay & stone</u> | <u>Surface</u> | <u>25</u> |
| <u>shalestone</u> | <u>25</u> | <u>80</u> |
| wood sandstone | 75 | 80 |
| <u>hard sandstone</u> | <u>80</u> | <u>140</u> |

6. DRILLHOLE

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
|------------|----------------|-----------|------------|------------|------------|
| <u>10</u> | <u>Surface</u> | <u>73</u> | <u>6</u> | <u>73</u> | <u>140</u> |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification & Method of Assembly | From (ft.) | To (ft.) |
|------------|---|----------------|-----------|
| <u>6</u> | <u>new black steel P.E. 18.97 A-53 Kent steel Pitless adapter</u> | <u>Surface</u> | <u>73</u> |

8. GROUT OR OTHER SEALING MATERIAL

| Kind | From (ft.) | To (ft.) |
|---------------|----------------|-----------|
| <u>Clay</u> | <u>Surface</u> | <u>8</u> |
| <u>Cement</u> | <u>8</u> | <u>73</u> |

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 80 Ft.

Depth of water level when pumping 96 Ft. Stabilized Yes No

Well construction completed on 8-20-1979

Well is terminated 10 inches above final grade below

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-27-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address R2 Box 4 Boscobel, Wisc. 53805

1008