

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

JUN 5 1979
MAY 29 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input type="checkbox"/> Town <input checked="" type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Ferryville</u>	
2. LOCATION		1/4 Section 1E	Section <u>8</u>	Township <u>10 N</u>	Range <u>6 W</u>
OR - Grid or Street No. <u>8E</u>		Street Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Brent Hutson</u>	
AND - If available subdivision name lot & block No. <u>4</u>				ADDRESS <u>Ferryville</u>	
				POST OFFICE <u>WV, 54628</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>15'</u>	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer
		Storm Bldg. Drain C.I. Other	Storm Bldg. Sewer C.I. Other	Storm Bldg. Drain C.I. Other	Storm Bldg. Sewer C.I. Other
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump	
Sewage Sump Clearwater Sump		Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench			
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
Barn Gutter		Animal Barn Pen		Animal Yard Silo With Pit	
Glass Lined Storage Facility		Silo w/o Pit		Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description) <u>City sewer 150'</u>	
5. Well is intended to supply water for: <u>home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind From (ft.) To (ft.)		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>73</u>	<u>6</u>	<u>73</u>	<u>100</u>
			<u>Clay & stone</u> <u>Surface</u> <u>0</u> <u>50</u>		
			<u>hard sandstone</u> <u>50</u> <u>100</u>		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
Dia. (in.)					
<u>6</u>	<u>new black steel P.F. 18.97 A-53</u>		<u>Surface</u>		<u>73</u>
<u>Valley Steel</u>					
<u>Pitless adapter</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary		
<u>Clay</u> <u>Surface</u> <u>0</u> <u>7</u>					
<u>Cement</u> <u>7</u> <u>73</u>			Well construction completed on <u>4-28-1979</u>		
11. MISCELLANEOUS DATA			Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Yield Test: <u>2</u> Hrs. at <u>5</u> GPM			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <u>60</u> Ft.			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>72</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u>			laboratory on <u>5-21-1979</u>		

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boacobel, WV, R3 Box 84 53805