

FEB 24 1972

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION - 1/4 Section SW Section 10 Township 10N Range 6W 3. OWNER AT TIME OF DRILLING David Coopers

OR - Grid or street no. Street name ADDRESS RI

AND - If available subdivision name, lot & block no. POST OFFICE Ferrysville, Wis., 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>12'</u>	<u>15'</u>	<u>20'</u>				

CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILD	ABANDONED WELL	SINK HOLE
	<u>60'</u>			<u>70'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>67</u>	<u>6</u>	<u>67</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>30</u>	
						<u>hard shale stone</u>	<u>30</u>	<u>55</u>	
						<u>sandstone</u>	<u>55</u>	<u>100</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>67</u>

8. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>30</u>
<u>Cement</u>	<u>30</u>	<u>67</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on Feb 1 19 72

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 12 GPM

Depth from surface to normal water level 70 ft.

Depth to water level when pumping 75 ft.

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 2-21- 19 72

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Coopers Registered Well Driller COMPLETE MAIL ADDRESS Booscobel, Wis., 53805

R3 Box 84

Please do not write in space below

COLIFORM TEST RESULT <u>1018</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-------------------------------------	---------------	---------------	-----------	---------