

WELL CONSTRUCTOR'S REPORT

Well-6

MAY 7 1970

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

CR-159-U

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE 1/4 of Sec. 10 T10N R6W

3. OWNER AT TIME OF DRILLING David Lieurance

4. OWNER'S COMPLETE MAIL ADDRESS R 7 D Ferryville, Wis., 54628

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
40'	45'				45'	

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		60'			65'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Trailer home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	47	6	47	180	Clay	Surface	15
						limestone	15	90
						shalestone	90	140
						sandstone	140	180

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	47

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
Cement	15	47

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 12 GPM

Well construction completed on 8-30-1969

Well is terminated 9 inches above below final grade

Depth from surface to normal water level 115 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 120 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison, Wis. laboratory on: 5-4-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coyian Registered Well Driller COMPLETE MAIL ADDRESS Boacoba, R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
1021				