

FEB 24 1978

State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

FEB 20 1978

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

NOTE:

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION NW Section 16 Township 10N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Lonnie Hutson

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Ferrisville, Wis. 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) 25'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected to:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other	Clearwater Sump	Septic Tank	Holding Tank	Seepage Pit	Seepage Bed	Seepage Trench	<u>75'</u>	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)					

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>97</u>	<u>6</u>	<u>97</u>	<u>120</u>	<u>Clay</u>	<u>Surface</u>	<u>2</u>
						<u>Clay & sand</u>	<u>2</u>	<u>80</u>
						<u>sandstone</u>	<u>80</u>	<u>120</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel R.E. 18.97</u>	<u>0</u> Surface	<u>97</u>
	<u>A-53</u>		
	<u>Valley Steel</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>2</u>
<u>Cement</u>	<u>2</u>	<u>97</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 1-27-1978

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 60 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 72 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 2-13-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature

Kenneth Coplan Registered Well Driller
1031

Complete Mail Address

R 3 Box 84 Boocedal, Wis. 53805