

OCT 19 1976

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

OCT 5 1976

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Freeman

2. LOCATION 1/4 Section SE Section 35 Township 10N Range 6W

3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
Joe Meyer  
ADDRESS R 1  
POST OFFICE Ferrisville, WI 54628

OR - Grid or Street No. Street Name  
AND - If available subdivision name, lot & block No.

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm C.I. Other  
Other Sewers: C.I. Other  
Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump  
Sewage Sump: C.I. Other  
Clearwater Sump  
Septic Tank: 50'  
Holding Tank  
Sewage Absorption Unit: 170'  
Seepage Pit  
Seepage Bed  
Seepage Trench

Privy: Pet Waste Pit  
Pit: Nonconforming Existing Well Pump Tank  
Subsurface Pumproom: Nonconforming Existing  
Barn Gutter: 75'  
Animal Barn Pen  
Animal Yard  
Silo With Pit: 85'  
Glass Lined Storage Facility  
Silo w/o Pit  
Earthen Silage Storage Trench Or Pit

Temporary Manure Stack  
Watertight Liquid Manure Tank  
Solid Manure Storage Structure  
Subsurface Gasoline or Oil Tank  
Waste Pond or Land Disposal Unit (Specify Type)  
Other (Give Description)

5. Well is intended to supply water for: Farm Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>57</u>	<u>6</u>	<u>57</u>	<u>100</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>20</u>
<u>Limestone</u>	<u>20</u>	<u>35</u>
<u>Hard Shalestone</u>	<u>35</u>	<u>100</u>
	<u>80</u>	

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>P.E. new Blacksteel 18.97</u>	<u>0</u> Surface	<u>57</u>
	<u>Valleysteel A-55</u>		
	<u>Pitless Adapter</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>57</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drifting mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on Sept. 14 1976

11. MISCELLANEOUS DATA

Yield Test: 5 Hrs. at 5 GPM

Depth from surface to normal water level 40 Ft.

Depth of water level when pumping 56 Ft. Stabilized  Yes  No

Well is terminated 12 inches  above final grade  below

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on Sept. 27 1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Corpien Registered Well Driller Complete Mail Address R3-Box 84 - Boscobel, WI 53805