

1. COUNTY: Crawford Crawford CHECK ONE:  Town  Village  City NAME: Clayton

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
Section 19 Town 11N Range 3W.

3. OWNER AT TIME OF DRILLING  
Paul Scheckel

4. OWNER'S COMPLETE MAIL ADDRESS  
Soldiers Grove

5. Distance in feet from well to nearest:  
 (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN
C. I.	TILE	C. I.	TILE
15			

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	60			75	200			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for:  
Farm

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	90				Drift	Surface	15
6	90	148				15 Green Shale	15	90

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	Pipe 19.45	Surface	90

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Cement	Surface	90

11. MISCELLANEOUS DATA

Well construction completed on 9/20 1966

Yield test: 8 Hrs. at 12 GPM Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 51 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 53 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: Sept. 28 1966

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE: Duane Lubbers Registered Well Driller COMPLETE MAIL ADDRESS: Farmersburg, Iowa

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
1042				

