

FEB 26 1970

WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City North Clayton NAME

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE 1/4 of Sec. 23 T11N R3W

3. OWNER AT TIME OF DRILLING Harold Olson

4. OWNER'S COMPLETE MAIL ADDRESS R7D Soldiers Grove, Wis. 54655

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
10'	15'	15'				25'

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		65'		80'		150'			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	43	6	43	100	Clay	Surface	10
						loose stone & clay	10	30
						hard shalestone	30	70
						limestone	70	100

9. GROUT OR OTHER SEALING MATERIAL			
Kind	From (ft.)	To (ft.)	
Clay	Surface	10	
Cement	10	43	

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 12 GPM

Well construction completed on 10-7-1969

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 48 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 50 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: Feb. 23-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boesobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
1046				