

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

AUG 7 1979

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Clayton	
2. LOCATION OR - Grid or Street No. SW 27 11N 3W AND - If available subdivision name, lot & block No.		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Jim Devitt		ADDRESS Soldiers Grove POST OFFICE Wis. 54655	
4. Distance in feet from well to nearest: (Record answer in appropriate block) 15'		Building Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
Street Sewer San. Storm C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. C.I. Other		Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 60' Seepage Pit Seepage Bed Seepage Trench	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)	
5. Well is intended to supply water for: Country Cabin			9. FORMATIONS		
6. DRILLHOLE			Kind From (ft.) To (ft.)		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	40	6	40	80
	Surface				
			loose rock & clay Surface 0 10		
			soft shalestone 10 25		
			hard shalestone 25 80		
7. CASING, LINER, CURBING AND SCREEN			10. TYPE OF DRILLING MACHINE USED		
Material, Weight, Specification & Method of Assembly			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
Dia. (in.)	From (ft.)	To (ft.)	Well construction completed on 7-24-1979		
6	0	40	Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
	Surface		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
new black steel P.E. 18.97 A-53			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Valley Steel Pitless adapter			Water sample sent to Madison laboratory on 8-2-1979		
8. GROUT OR OTHER SEALING MATERIAL			11. MISCELLANEOUS DATA		
Kind		From (ft.)	To (ft.)	Yield Test: 2 Hrs. at 5 GPM	
Clay		0	7	Depth from surface to normal water level 46 Ft.	
Cement		7	40	Depth of water level when pumping 52 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.			Signature Kenneth Copian Registered Well Driller		
			Complete Mail Address Boscobel, Wis. R2 Box 4 53805		