

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

JUL 23 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Utica</u>	
2. LOCATION OR - Grid or Street No. Street Name		1/2 Section <u>SW</u> Section <u>19</u> Township <u>11 N</u> Range <u>4 W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Dave Renn</u>	
AND - If available subdivision name, lot & block No.		ADDRESS <u>RFD</u>		POST OFFICE <u>Soldiers Grove Wis. 54655</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>8'</u>		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
		Sewage Sump Clearwater Sump		Sewage Sump C.I. Other	
		Clearwater Dr.		Clearwater Sump	
Privy		Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank	
		Subsurface Pumproom Nonconforming Existing		Barn Gutter	
		Animal Barn Pen		Animal Yard	
		Silo With Pit		Glass Lined Storage Facility	
		Silo w/o Pit		Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: <u>Country home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>loose stone & Clay</u>		<u>Surface 0 30</u>	
<u>10 0 75 6 75 140</u>		<u>soft shale stone</u>		<u>30 60</u>	
		<u>hard shale stone</u>		<u>60 140</u>	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
Dia. (in.)					
<u>6 new black steel R.F. 18.97</u>		<u>0 Surface 75</u>			
<u>A-53</u>					
<u>Kent Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary hammer w/drilling mud & air	
<u>Clay 0 7</u>		<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary hammer & air	
<u>Cement 7 75</u>		<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary	
				<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
11. MISCELLANEOUS DATA		Well construction completed on <u>7-7-79</u>			
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM		Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level <u>95</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>98</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <u>Madison</u> laboratory on <u>7-17-79</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Coplan</u> Registered Well Driller		Complete Mail Address <u>Roseobel, Wis. R2 Box 4 53805</u>			

1065