

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name JUN 16 1983 Haney

2. LOCATION NE 1/4 Sec. 23 Section 9N Township 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Dan Galatzer

OR SW Sec. 23 Street or Road Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Boscobel Wis ZIP CODE 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer	Other Sewers	Foundation Drain Connected to:		Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	C.I.	Other	Seepage Pit	Seepage Bed
				Clearwater Sump				Seepage Trench	

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank

Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	79	6	79	360	clay rock	Surface	12
						lime rock	12	180
						shale	180	360

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	new black steel	PE 18.97	Surface	79
	A120 1200 psi	Valley steel		
	Pitless adaptor			

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	79

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 4-25 1983

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 300 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 305 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-4 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kinoshan Registered Well Driller Business Name and Complete Mailing Address Dons Well Drilling Boscobel Wis 53805