

WELL CONSTRUCTOR'S REPORT

JUL 9 1970

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE 1/4 of Sec. 25 T11N R4E W0

3. OWNER AT TIME OF DRILLING Lester Wenger

4. OWNER'S COMPLETE MAIL ADDRESS R7D Soldiers Grove, Wis. 54655

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.
10'	15'	15'			

CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARE	SILCO	ABANDONED WELL	SINK HOLE
	85'		100'		125'		65'	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS			
Dis. (in.)	From (ft.)	To (ft.)	Dis. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	63	6	63	100	Clay	Surface	30	
						sandy soil	30	55	
						hard shalestone	55	75	
						sandrock	75	100	

8. CASING, LINER, CURBING, AND SCREEN			
Dis. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	63

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	30
Cement	30	63

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 64 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 7-6-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boacabel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
107.4				