

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

7779

SEP 21 1972

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section SE Section 26 Township 11N Range 4W 3. OWNER AT TIME OF DRILLING Mr. & Mrs. Martin Baker

OR - Grid or street no. Street name ADDRESS R1 Box 17

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block)

| | | | | |
|------------|----------------|-------------|------------------|-------------------|
| BUILDING | SANITARY SEWER | FLOOR DRAIN | FOUNDATION DRAIN | WASTE WATER DRAIN |
| C.I. | C.I. | C.I. | SEWER CONNECTED | INDEPENDENT |
| TILE | TILE | TILE | | |
| <u>10'</u> | <u>20'</u> | <u>20'</u> | | |

| | | | | | | | | |
|-------------------|-------------|-------|-------------|------------------|------|------|----------------|-----------|
| CLEAR WATER DRAIN | SEPTIC TANK | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN | SILO | ABANDONED WELL | SINK HOLE |
| C.I. | TILE | | | | | | | |
| | <u>65'</u> | | | <u>80'</u> | | | | |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

| 6. DRILLHOLE | | | | | | 9. FORMATIONS | | |
|--------------|----------------|-----------|------------|------------|------------|------------------------|----------------|------------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| <u>10</u> | <u>Surface</u> | <u>42</u> | <u>6</u> | <u>42</u> | <u>460</u> | <u>Clay</u> | <u>Surface</u> | <u>8</u> |
| | | | | | | <u>limestone</u> | <u>8</u> | <u>150</u> |
| | | | | | | <u>hard sandstone</u> | <u>150</u> | <u>255</u> |
| | | | | | | <u>hard shalestone</u> | <u>255</u> | <u>405</u> |
| | | | | | | <u>sandstone</u> | <u>405</u> | <u>460</u> |

| 7. CASING, LINER, CURBING, AND SCREEN | | | |
|---------------------------------------|--|----------------|-----------|
| Dia. (in.) | Kind and Weight | From (ft.) | To (ft.) |
| <u>6</u> | <u>new black steel plain end 19.18</u> | <u>Surface</u> | <u>42</u> |

| 8. GROUT OR OTHER SEALING MATERIAL | | | 10. TYPE OF DRILLING MACHINE USED | | |
|------------------------------------|----------------|-----------|--|---|---|
| Kind | From (ft.) | To (ft.) | <input type="checkbox"/> Cable Tool | <input type="checkbox"/> Direct Rotary | <input type="checkbox"/> Reverse Rotary |
| <u>Clay</u> | <u>Surface</u> | <u>8</u> | <input type="checkbox"/> Rotary - air w/drilling mud | <input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air | <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water |
| <u>Cement</u> | <u>8</u> | <u>42</u> | Well construction completed on <u>9-7-1972</u> | | |

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 400 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 405 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-18-1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Booscobel, Wis., 53805
R3 Box 84

COLIFORM TEST RESULT 1075 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71