

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

FEB - 2 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Utica</u>	
2. LOCATION OR - Grid or Street No. <u>SW</u> Section <u>30</u> Township <u>11N</u> Range <u>4W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Daniel R. Kerr</u>		ADDRESS <u>R1 Box 32B</u>	
AND - If available subdivision name, lot & block No.		POST OFFICE <u>Soldiers Grove, WI 54655</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>35'</u>		Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
Sewage Sump C.I. Other		Clearwater Sump		Sewage Absorption Unit <u>75'</u> Seepage Pit Seepage Bed Seepage Trench	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: <u>Country home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
<u>10</u> <u>Surface</u> <u>51</u>			<u>Clay Limestone</u> <u>Surface</u> <u>10</u>		
<u>6</u> <u>51</u> <u>120</u>			<u>limestone</u> <u>10</u> <u>30</u>		
			<u>hard shalestone</u> <u>30</u> <u>100</u>		
			<u>sandstone</u> <u>100</u> <u>120</u>		
7. CASING, LINER, CURBING AND SCREEN					
Dia. (in.) Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
<u>6</u> <u>new black steel</u>			<u>Surface</u> <u>51</u>		
<u>P.F. 18.97</u>					
<u>A-53</u>					
<u>Kent Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
<u>Clay</u> <u>Surface</u> <u>0</u> <u>7</u>			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
<u>Cement</u> <u>7</u> <u>51</u>			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
11. MISCELLANEOUS DATA			Well construction completed on <u>12-30-</u> <u>1978</u>		
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM			Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level <u>80</u> Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>86</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>1-29-</u> <u>1979</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Coplan</u> Registered Well Driller			Complete Mail Address <u>Boocobee, WI</u> <u>R3 Box 84</u> <u>53805</u>		

1078