

OCT 20 1981

SEP 24 1981

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Nancy WCD

2. LOCATION SW Section 32 Township 9N Range 4E 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Dale Kunder

OR - Grid or Street No. Street or Road Name ADDRESS RR1

AND - If available subdivision name, lot & block No. POST OFFICE Stueben, WI ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>25</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other
		<u>40</u>			

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Pit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer	Sewage Sump Clearwater Sump	Clearwater Sump			<u>75</u>	
		Clearwater Dr.			<u>50</u>		Seepage Pit Seepage Bed Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: mobile home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>81</u>	<u>6</u>	<u>81</u>	<u>140</u>	<u>loose limestone</u>	<u>Surface</u>	<u>43</u>
						<u>soft shale</u>	<u>43</u>	<u>65</u>
						<u>hard shale</u>	<u>65</u>	<u>140</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>A-53 P.E.</u> <u>#18.974</u> <u>patless adapter</u> <u>Kent Steel</u>	<u>Surface</u>	<u>81</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>81</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 3-27 1981

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 8 GPM Well is terminated 15 inches above final grade below

Depth from surface to normal water level 90 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 94 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 9-21 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Corpiant Registered Well Driller Business Name and Complete Mailing Address Kenneth Corpiant Sons, Inc
Rt. 2 Box 4 Boscobel, WI 53805