

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

OCT 4 1978

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION 1/4 Section SW Section 19 Township 11N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Robert Boyer

OR - Grid or Street No. Street Name ADDRESS R1 Box 174

AND - If available subdivision name, lot & block No. POST OFFICE Lyndville, W.V., 54640

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 150' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit 95' Seepage Pit Seepage Bed Seepage Trench

Septic Tank 85' Holding Tank Sewage Absorption Unit 95'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	181	6	181	300

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	72
broken limestone	72	165
hard sandstone	165	300

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel R.E. 18.97 A-53 Valley Steel	Surface	181

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Rotary-hammer & air Reverse Rotary Jetting with Air Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
top soil	Surface	2
Cement	2	181

Well construction completed on 9-12-1978

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 210 Ft.

Depth of water level when pumping 235 Ft. Stabilized Yes No

Well is terminated 12 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 9-28-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, W.V. R3 Box 84 53805