

WCD

JUN 25 1981

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name HANEY

2. LOCATION 1/4 Section SW Section 32 Township 9N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Dale Kinder

OR - Grid or Street No. Street Name ADDRESS RR 1

AND - If available subdivision name, lot & block No. POST OFFICE Stueben, WI

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25 Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other 40 Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to Sewer Clearwater Dr. Sewage Sump C.I. Other Sewage Sump Clearwater Sump Clearwater Sump Clearwater Sump Holding Tank Septic Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 75'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: mobile home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	0 Surface	81	6	81	140	loose limestone	0 Surface	43
						soft shale	43	65
						hard shale	65	140

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	A-53 P.E. 18.97"/ft. pitless adapter	0 Surface	81

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	0 Surface	8
Cement	8	81

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 3-27 1981

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 8 GPM Well is terminated 15 inches above final grade below

Depth from surface to normal water level 90 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 94 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-10 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phillip S. Coplan Registered Well Driller Complete Mail Address 308 E. Bluff
Boscobel, WI 53805