

MAY 1 1979

State of Wisconsin  
Department of Natural Resources  
Box 7921  
Madison, Wisconsin 53707

NOTE:  
White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Utica

2. LOCATION NE Section 26 Township 11N Range 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
Harry Mracek

OR - Grid or Street No. Street Name ADDRESS R1

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wisc. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 7'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer  San.  Storm  Other Sewers  C.I.  Other  Foundation Drain Connected to: Sewage Sump  Clearwater Dr.  Sewage Sump  Clearwater Sump  Sewage Sump  Clearwater Sump

Clearwater Sump 50' Holding Tank  Sewage Absorption Unit 55'  
Seepage Pit  Seepage Bed  Seepage Trench

Privy  Pet Waste Pit  Pit: Nonconforming Existing  Well Pump Tank  Subsurface Pumproom Nonconforming Existing  Barn Gutter 200' Animal Barn Pen  Animal Yard  Silo With Pit 200' Glass Lined Storage Facility  Silo w/o Pit  Earthen Silage Storage Trench Or Pit

Temporary Manure Stack  Watertight Liquid Manure Tank  Solid Manure Storage Structure  Subsurface Gasoline or Oil Tank  Waste Pond or Land Disposal Unit (Specify Type)  Other (Give Description)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>48</u>	<u>6</u>	<u>48</u>	<u>80</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>loose stone</u>	<u>7</u>	<u>35</u>
<u>hard sandstone</u>	<u>35</u>	<u>80</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel R.E. 18.97</u>	<u>Surface</u>	<u>48</u>
	<u>A-53</u>		
	<u>Kent Steel</u>		
	<u>Pitless adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>48</u>

Well construction completed on 4-10-1979

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 5 GPM

Well is terminated 10 inches  above final grade  below

Depth from surface to normal water level 50 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 58 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 4-23-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cyprian Registered Well Driller Complete Mail Address Boscobel, Wisc. R3 Box 84 53805

1104