

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

001 3 10

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Freeman

2. LOCATION - 1/4 Section SE Section 33 Township 11N Range 5W 3. OWNER AT TIME OF DRILLING Norman Chaplin  
OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Ferrisville, Wis. 54628

4. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN  
(Record answer in appropriate block) 12' 15' C.I. TILE C.I. TILE SEWER CONNECTED INDEPENDENT C.I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE  
C.I. TILE 60' 68'

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	40	6	40	100	Clay	Surface	12	
						loose rock & clay	12	30	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	40

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)  
Clay Surface 12  
Cement 12 40

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with Air  Water

11. MISCELLANEOUS DATA  
Yield test: 3 Hrs. at 8 GPM  
Well construction completed on 9-25-1973  
Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 54 ft. Well disinfected upon completion  Yes  No  
Depth to water level when pumping 60 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 10-2-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis., R3 Box 84 53805  
Please do not write in space below

COLIFORM TEST RESULT <u>1108</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-------------------------------------	---------------	---------------	-----------	---------