

**WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH**  
See Instructions on Reverse Side

RECEIVED  
AUG 31 1951  
S. B. FREAC  
ENGL

1. County Crawford Town Freeman  
 2. Location N.W. of N.W. 1/4 Sec. 33, T 11N, R. 5W. Village \_\_\_\_\_  
 3. Owner or Agent Ralph Jorgenson City \_\_\_\_\_  
 4. Address R. 1, Ferryville, Wis.  
 5. From well to nearest: Building 6 ft; sewer \_\_\_\_\_ ft; drain \_\_\_\_\_ ft; septic tank 100 ft;  
 dry well or filter bed \_\_\_\_\_ ft; abandoned well \_\_\_\_\_ ft.  
 6. Well is intended to supply water for: Home and Farm

**7. DRILLHOLE OR EXCAVATION:**

Dis. (in.)	From (ft.)	To (ft.)
6	0	70

**10. FORMATIONS:**

Kind	Thick-ness (ft.)	Total Depth (ft.)
Top Soil & Gravel	15	15
Sand Rock	45	60
shale	10	70

**8. CASING AND LINER PIPE OR CURBING:**

Dis. (in.)	Kind	From (ft.)	To (ft.)
6	Standard	0	32

**9. GROUT:**

Kind	From (ft.)	To (ft.)

**11. MISCELLANEOUS DATA:**

Yield test: 2 Hrs. at 5 GPM.  
 Depth from surface to water: 32 ft.  
 Water-level when pumping: 32 ft.  
 Water sample sent to laboratory at  
Madison on Aug 1 1951

Construction of the well was completed on June 23 1951

The well is terminated 12 inches (above) (below) the permanent grade.

Was the well disinfected upon completion?  
 Yes X No \_\_\_\_\_

Was the well sealed watertight upon completion?  
 Yes X No \_\_\_\_\_

Signature Joseph Dall  
 Registered Well Driller

Waupesa, Wis.  
 Complete Mail Address