

MAY 21 1973

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			NAME <i>Freeman</i>	
2. LOCATION - $\frac{1}{4}$ Section Section Township Range <i>NE 21 11N 6W</i>				3. OWNER AT TIME OF DRILLING <i>Mr. Horace West</i>		
OR - Grid or street no.		Street name		ADDRESS <i>R7D1</i>		
AND - If available subdivision name, lot & block no.				POST OFFICE <i>Ferryville, Wis.</i>		
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C. I.	SANITARY TILE	SEWER TILE	FLOOR DRAIN C. I.	TILE
		<i>25'</i>				
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO
		<i>125'</i>			<i>100'</i>	
						<i>25'</i>
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)						

5. Well is intended to supply water for: *Country home*

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<i>10</i>	<i>Surface</i>	<i>65</i>	<i>6</i>	<i>65</i>	<i>400</i>	<i>Clay</i>	<i>Surface</i>	<i>25</i>	
						<i>soft sand</i>	<i>25</i>	<i>35</i>	
						<i>limestone &amp; clay</i>	<i>35</i>	<i>55</i>	
						<i>limestone</i>	<i>55</i>	<i>230</i>	
						<i>sandstone</i>	<i>230</i>	<i>290</i>	
						<i>limestone</i>	<i>290</i>	<i>360</i>	
						<i>shalestone</i>	<i>360</i>	<i>400</i>	

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<i>Clay</i>	<i>Surface</i>	<i>25</i>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<i>Cement</i>	<i>25</i>	<i>65</i>	Well construction completed on <i>4-17-</i> 19 <i>73</i>		

11. MISCELLANEOUS DATA		Yield test: <i>8</i> Hrs. at <i>6</i> GPM		Well is terminated <i>15</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Depth from surface to normal water level <i>325</i> ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth to water level when pumping <i>325</i> ft.		Water sample sent to <i>Madison</i> laboratory on: <i>5-16-</i> 19 <i>73</i>			

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Copian</i> Registered Well Driller	COMPLETE MAIL ADDRESS <i>R3 Box 84 Boscobel, Wis. 53805</i>
--	--

COLIFORM TEST RESULT <i>1112</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				