

JUN 16 1983

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Honey

2. LOCATION NE of NW Section 34 Township 9N4W Range R4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Eldon Pittsley

OR - Grid or Street No. Street or Road Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Lays Mills Wi ZIP CODE 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Other Sewage Sump Clearwater Sump Clearwater Sump Clearwater Sump Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

70' 80'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility No w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: house

6. DRILLHOLE

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
|------------|------------|----------|------------|------------|----------|
| 10 | Surface | 80 | 6 | 80 | 100 |

9. FORMATIONS

| Kind | From (ft.) | To (ft.) |
|-------------|------------|----------|
| clay | Surface | 30 |
| Clay & Rock | 30 | 60 |
| Shale | 60 | 100 |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification | From (ft.) | To (ft.) |
|------------|---|------------|----------|
| 6 | new black steel PE 18.97 ASTM A120 1200PSI Valley Steel Pitless adaptor | Surface | 80 |

8. GROUT OR OTHER SEALING MATERIAL

| Kind | From (ft.) | To (ft.) |
|--------|------------|----------|
| clay | Surface | 8 |
| cement | 8 | 80 |

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM

Depth from surface to normal water level 75 Ft.

Depth of water level when pumping 80 Ft. Stabilized Yes No

Well construction completed on 4-26 19 83

Well is terminated 12 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-31 19 83

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address Box 75 Dons Well Drilling Boscobel Wi 53805

CR 112