

MAY 18 1977

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION ¼ Section NE Section 35 Township 11 N Range 7 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Thomas A. Erb

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE De Soto, Wis. 54624

4. Distance in feet from well to nearest: (Record answer in appropriate block) 10'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer	Other Sewers	Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Sewage Sump	Clearwater Sump			Seepage Pit	
				Clearwater Dr.	Clearwater Sump				Seepage Bed	
									Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well	Nonconforming Existing							
		Pump								
		Tank								

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	175	6	175	570

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay & stone	Surface	65
limestone	65	92
soft sandstone	92	160
limestone	160	380
hard shalestone	380	520
sandstone	520	570

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	175

Pitless adapter
Valley Steel

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	175

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM

Depth from surface to normal water level 475 Ft.

Depth of water level when pumping 495 Ft. Stabilized Yes No

Well construction completed on 5-2-1977

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-16-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 1130
Kenneth Coplan
Registered Well Driller

Complete Mail Address Boscobel, Wis.,
R3 Box 84
53805