State of Wisconsin
Department of Natural Resources
Private Water Supply
Box 7921
Madison, Wisconsin 53707

NOTE:
White Copy – Division's Copy
Green Copy – Driller's Copy
Yellow Copy – Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300–15 Rev. 2-79

MAR 2 7 1985

1. COUNTY: Crawford
CHECK (✓) ONE: ☑ Town ☐ Village ☐ City
Name: Seneca

2. LOCATION: ¼ Section or Gov't. Lot: SE of NW | Section: 3 | Township: 9N | Range: 5W
OR – Grid or Street No. | Street or Road Name
AND – If available subdivision name, lot & block No.

3. NAME ☑ OWNER ☐ AGENT AT TIME OF DRILLING CHECK (✓) ONE: Bernard Zach
ADDRESS: Rt 1
POST OFFICE: Gays Mills Wi
ZIP CODE: 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other
451										

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pnuematic Tank
San.	Storm	C.I.	Other			C.I.	Other				Seepage Pit	
				Sewer		Sewage Sump			63'		Seepage Bed	
				Clearwater Dr.		Clearwater Sump					Seepage Trench 70'	

Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well										
		Pump										
		Tank										

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls	Other (Describe)

5. Well is intended to supply water for: country homes

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	290	6	290	340

7. CASING, LINER, CURBING AND SCREEN
Material, Weight, Specification

Dia. (in.)	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	new black steel PE 18.97	Surface	290
	PSI 1200		
	A-120		
	USP		
	Pitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	290

9. FORMATIONS

Kind	From (ft.)	To (ft.)
clay	Surface	5
lime rock	5	70
sand rock	70	130
lime rock	130	240
shale	240	325
sand rock	325	340

10. TYPE OF DRILLING MACHINE USED
☐ Cable Tool
☐ Rotary-air w/drilling mud
☐ Rotary-w/drilling mud
☐ Rotary-hammer w/drilling mud & air
☑ Rotary-hammer & air
☐ Reverse Rotary
☐ Jetting with Air ☐ Water

Well construction completed on 8–15– 19 84

11. MISCELLANEOUS DATA
Yield Test: 3 Hrs. at 7 GPM
Depth from surface to normal water level 290 Ft.
Depth of water level when pumping 292 Ft. Stabilized ☑ Yes ☐ No

Well is terminated 12 inches ☑ above ☐ below final grade
Well disinfected upon completion ☑ Yes ☐ No
Well sealed watertight upon completion ☑ Yes ☐ No

Water sample sent to Madison laboratory on 3–18– 19 85

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature
114 Donald C. Kirschbaum Registered Well Driller

Business Name and Complete Mailing Address Rt 4 Box 75
Dons Well Drilling Boscobel Wi, 53805