

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

AUG 27 1980

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Seneca	
2. LOCATION 1/4 Section NW Section 7 Township 9N Range 5W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Donald Cutler			
OR - Grid or Street No. Street Name		ADDRESS			
AND - If available subdivision name, lot & block No.		POST OFFICE Cross Plains, Wisconsin 53528			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 30		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
				Sewage Sump Clearwater Sump	
				Clearwater Sump	
				Septic Tank Holding Tank	
				Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 80	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
				Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: Private Residence			9. FORMATIONS		
			Kind From (ft.) To (ft.)		
6. DRILLHOLE			Clay Surface 25		
Dia. (in.) From (ft.) To (ft.)			Broken Magnesia Limestone 25 165		
10 Surface 167			Magnesia Limestone 165 290		
6 167 500			Sandstone 290 380		
7. CASING, LINER, CURBING AND SCREEN			Shalestone 380 500		
Material, Weight, Specification & Method of Assembly					
Dia. (in.) From (ft.) To (ft.)					
6 New black st'd steel Surface 167					
18.97# P.E. Welded					
ASTM A53 .280 W.T.					
Sumitomo					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
Neat Cement Surface 167			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
			Well construction completed on 8/19 19 80		
11. MISCELLANEOUS DATA			Yield Test: 3 Hrs. at 15 GPM		
Depth from surface to normal water level 415 Ft.			Well is terminated 12 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth of water level when pumping 425 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to Madison, Wisconsin laboratory on 8/19 19 80			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature : Dean Rickard <i>Dean Rickard</i> Registered Well Driller			Complete Mail Address Box 93 Linden, Wisconsin 53553		

116

WGNHS ORIGINAL