

FEB 18 1983

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **WAUZEKA**

2. LOCATION **SW 1/4 E 1/2 SW 2 T7N 5W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **HOWARD ROTH**

OR - Grid or Street No. **R4W** Street or Road Name **RFD 1 WAUZEKA, WI** ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE **53826** ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building **75'**

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank		
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other	C.I.	Other	C.I.	Other	Seepage Pit	Seepage Bed	Seepage Trench		

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Well	Pump	Tank	Subsurface Pumproom	Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
-------	---------------	-----------------------------	------	------	------	---------------------	------------------------	-------------	-----------------	-------------	---------------	------------------------------	--------------	--------------------------------------	----------------------

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only	Concrete Floor and Partial Concrete Walls

5. Well is intended to supply water for: **FARM**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	76			
6"	76	180			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	NEW BLACK STEEL PLAIN END 18.97	Surface	76
	A-53 VALLEY STEEL		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
CLAY & LOOSE ROCK	Surface	51
HARD SHALE STONE	51	93
LIMESTONE	93	107
HARD SHALE STONE	107	180

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
CEMENT	8 Surface	76
BARRY TANK	0	8

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on **2.1.83** 19

11. MISCELLANEOUS DATA

Yield Test: **3** Hrs. at **10** GPM

Well is terminated **8** inches above final grade below

Depth from surface to normal water level **80** Ft.

Depth of water level when pumping **72** Ft. Stabilized Yes No

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to **MADISON WI** laboratory on **2.14 1983**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Kenneth Coyjian** Registered Well Driller

Business Name and Complete Mailing Address **KENNETH COYJIAN & SONS INC. RT. 2 BOX 4 BOSCOBEL, WI 53500**