

JUL 24 1981  
 SEP 1 1981  
 wcd

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Seneca

2. LOCATION NE, NW Section 18 Township 9N Range 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Francis M. Struschein

OR - Grid or Street No. Street or Road Name ADDRESS 461 Birchwood Dr.

AND - If available subdivision name, lot & block No. POST OFFICE Antioch, Ill. ZIP CODE 60002

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 35

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank	
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other	Sump	Sump	Tank	Tank	Seepage Pit	Seepage Bed	Seepage Trench			

Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard		Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit		Earthen Silage Storage Trench Or Pit		Earthen Manure Basin	
		Well	Pump	Well	Pump	Nonconforming	Existing	Nonconforming	Existing														

Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)	
										Concrete Floor Only	Concrete Floor and Partial Concrete Walls		

5. Well is intended to supply water for: mobile home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
10	Surface	354	6	354	440	clay broken limestone	Surface	0	33
						crvice sandstone		33	148
						limestone clay pockets		148	340
						hard sandstone		340	440

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	P.E. 18.9 lbs/ft	A53 Livingston Pipe & Tube	Surface	354
		Pitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	354

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 6-19 1981

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 9 GPM

Well is terminated 15 inches  above final grade  below

Depth from surface to normal water level 380 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 385 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 7-15 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Corpian Registered Well Driller

Business Name and Complete Mailing Address Kenneth Corpian & Sons, Inc  
Rt. 2 Box 4 Boonville, WI 53805

120