

OCT 7 1983

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **SENECA**

2. LOCATION $\frac{1}{4}$ Section or Gov't. Lot **NW** Section **32** Township **T9N** Range **R5W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **LLOYD DUHA**

OR - Grid or Street No. Street or Road Name ADDRESS **RFD**

AND - If available subdivision name, lot & block No. POST OFFICE **EASTMAN, WI.** ZIP CODE **54626**

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building **50'** Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: **COUNTRY HOME**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	191			
6"	191	280			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	NEW BLACK STEEL PLAIN END	Surface	191
	A-53 18.97		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
DIRT LOOSE ROCK	Surface	17
SAND ROCK	17	55
LIMESTONE	55	180
HARD SANDSTONE	180	280

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
CEMENT	7 Surface	191
BURRY TANK	0	7

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on **9-15 1983**

11. MISCELLANEOUS DATA

Yield Test: **2** Hrs. at **8** GPM

Well is terminated **10** inches above final grade below

Depth from surface to normal water level **200** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **210** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON** laboratory on **10-3 1983**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Kenneth Corsian** Registered Well Driller

Business Name and Complete Mailing Address **CORSIAN WELL DRILLING RT. 2 BOX 4 BOSCOBEL, WI 53805**