

AUG 5 1985

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION NE of SE Section 1 Township 9N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Merrick Flamme

OR - Grid or Street No. Street or Road Name ADDRESS Rt 1 Box 212

AND - If available subdivision name, lot & block No. POST OFFICE Eastman ZIP CODE WI 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>181</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other	Clearwater Sump	80'		Seepage Pit Seepage Bed Seepage Trench <u>60'</u>	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumphouse	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>63</u>	<u>6</u>	<u>63</u>	<u>80</u>	<u>clay</u>	<u>Surface</u>	<u>30</u>
						<u>loose rock</u>	<u>30</u>	<u>45</u>
						<u>shale rock</u>	<u>45</u>	<u>80</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PE 18.97 PSI 1200 A-120 USP Drillis adaptor</u>	<u>Surface</u>	<u>63</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>cement</u>	<u>8</u>	<u>63</u>

9. FORMATIONS

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 4-10 1985

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 70 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 45 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-19 1985

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 125 Donald C. Kirschman Registered Well Driller Business Name and Complete Mailing Address Rt 4 Box 75 Dons Well Drilling Buschel WI 53805