

NOTE:  
White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

MAR 27 1985

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Lynxville

2. LOCATION SW of NW 13 9N 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
OR - Grid or Street No. Street or Road Name ADDRESS Rt 1

AND - If available subdivision name, lot & block No. POST OFFICE Eastman WI ZIP CODE 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>25'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr. Clearwater Sump	C.I. Other				Seepage Pit Seepage Bed Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>340</u>	<u>6</u>	<u>340</u>	<u>460</u>	<u>clay</u>	<u>Surface</u>	<u>35</u>
						<u>lime rock</u>	<u>35</u>	<u>250</u>
						<u>sand rock</u>	<u>250</u>	<u>330</u>
						<u>shale rock</u>	<u>330</u>	<u>460</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PE 1097</u>	<u>Surface</u>	<u>340</u>
	<u>PSI 1200</u>		
	<u>A-120</u>		
	<u>USP</u>		
	<u>pitless adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>cement</u>	<u>8</u>	<u>340</u>

Well construction completed on 11-2 19 84

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM

Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 410 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 415 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 11-13 19 84

Your opinion concerning other pollution hazards; information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 127 Donald C. Kirshman Registered Well Driller Business Name and Complete Mailing Address Rt 4 Box 75 Dons Well Drilling Escotell WI 53805