

MAY 13 1985

TOWN OF CLAYTON

1. COUNTY CRAWFORD CHECK (✓) ONE:  Town  Village  City Name WATERS TOWN  
GAYS MILLS

2. LOCATION SW 1/4, SE 1/4 Section 10N Township 3W Range 3W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
MIKE MC CORMICK

OR - Grid or Street No. Street or Road Name ADDRESS  
Sec 29 R.R. 2 Box 55

AND - If available subdivision name, lot & block No. POST OFFICE ZIP CODE  
GAYS MILLS WI. 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 39' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Clearwater Dr. Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed 150' Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: FARM HOME

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	0 Surface	284'			
6"	284'	360'			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	New Black Steel Plain End	0 Surface	284'
	18.97 United Steel CA Conduven		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
CLAY	0 Surface	3
LIME ROCK & CREVICE	3	174
SAND ROCK	174	279
SHALE	279	360

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	7 Surface	284
Pitless Adaptor	0	7

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 4-26 1985

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 10 inches  above final grade  below

Depth from surface to normal water level 270 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 300 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 5-8 1985

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

145 Signature Henneth Coprian Registered Well Driller Business Name and Complete Mailing Address CORPIAN WELL DRILLING  
R.R. 2 BOX BOSCOBEL, WI 53805