

NOTE:  
 White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Utica

2. LOCATION SW 1/4 NE 1/4 16 10N 4W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
John Pedersen  
 OR - Grid or Street No. Street or Road Name ADDRESS R.R.

AND - If available subdivision name, lot & block No. POST OFFICE May Mills ZIP CODE Wisc 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Septic Tank None Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed None Seepage Trench Manure Hopper or Retention or Pnuematic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Private 9. FORMATIONS

| 6. DRILLHOLE |            |          |            |            |          | 9. FORMATIONS |            |          |
|--------------|------------|----------|------------|------------|----------|---------------|------------|----------|
| Dia. (in.)   | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind          | From (ft.) | To (ft.) |
| 10           | 0          | 63       |            |            |          | Soft shale    | 13         | 57       |
| 6            | 63         | 120      |            |            |          | Hard shale    | 57         | 72       |
|              |            |          |            |            |          | Sand rock     | 72         | 120      |

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification  
 Dia. (in.) Mfg. & Method of Assembly From (ft.) To (ft.)  
6 New Black Steel Surface 63  
Plain End  
CAC ASTM A-120  
18.97 6x21  
.280 W

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)  
Bury Tank Surface 7  
Cement 7 63

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  
 Rotary-air w/drilling mud  Rotary-hammer & air  Air  
 Rotary-w/drilling mud  Reverse Rotary  Water

11. MISCELLANEOUS DATA Yield Test: 2 Hrs. at 7 GPM Well construction completed on 7-11 1987  
 Well is terminated 10 inches  above final grade  below

Depth from surface to normal water level 69 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 77 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to MADISON laboratory on 7-15 1987

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael D. Benbow Registered Well Driller Business Name and Complete Mailing Address CORRIAN Well Drilling  
R.R. 2 Boscobel WI. 53805