

001 18 1983

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION SE of NE 1/4 Section or Gov't. Lot Section 2 Township 10N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Robert Furber

OR - Grid or Street No. Street or Road Name ADDRESS Hayes Mills WI

AND - If available subdivision name, lot & block No. POST OFFICE ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>30'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other				Seepage Pit Seepage Bed Seepage Trench <u>68'</u>	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: trailer

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>0</u>	<u>42</u>	<u>6</u>	<u>42</u>	<u>100</u>	<u>clay shale</u>	<u>Surface</u>	<u>10</u>
						<u>sand rock</u>	<u>60</u>	<u>100</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PSI 1200 PE 1/4" #3/4" A-120</u>	<u>0</u>	<u>42</u>
	<u>Valley steel</u>		
	<u>Rittler adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>42</u>

Well construction completed on 7-28 1983

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 70 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 75 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-3 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address RT4 Box 75 Dons Well Drilling P.O. Box 53825