

NOV 4 1981

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <u>Clayton</u> WCP	
2. LOCATION <u>Southwest Pt</u>		Section <u>33</u>	Township <u>10N</u>	Range <u>4W</u>	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Jim Wielander</u>	
OR - Grid or Street No. Street or Road Name		ADDRESS <u>Rt 1</u>			POST OFFICE <u>Hays Mills</u> ZIP CODE <u>54631</u>	
AND - If available subdivision name, lot & block No.						
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>15'</u>	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer	Storm Bldg. Drain C.I. Other
Street Sewer San. Storm	Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump	Sewage Sump C.I. Other	Clearwater Sump	Septic Tank <u>55'</u>	Holding Tank
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls	Other (Describe)
5. Well is intended to supply water for: <u>Country Home</u>				9. FORMATIONS		
6. DRILLHOLE				Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	From (ft.) To (ft.)
<u>10</u>	<u>0</u> Surface	<u>105</u>	<u>6</u>	<u>105</u>	<u>420</u>	<u>0</u> <u>15</u> Surface
				<u>clay</u>		
				<u>lime rock</u>		
				<u>sand rock</u>		
				<u>shale stone</u>		
7. CASING, LINER, CURBING AND SCREEN						
Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)			
<u>6</u>	<u>new black steel</u> <u>PE - 18.97</u>	<u>0</u> Surface	<u>105</u>			
<u>A-53</u>						
<u>Valley Steel</u>						
<u>Pitless adaptor</u>						
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED		
Kind		From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
<u>clay</u>		<u>0</u> Surface	<u>8</u>			
<u>cement</u>		<u>8</u>	<u>105</u>			
11. MISCELLANEOUS DATA				Well construction completed on <u>Oct. 26</u> 19 <u>81</u>		
Yield Test: <u>3</u>	Hrs. at <u>8</u>	GPM	Well is terminated <u>12</u> inches	<input checked="" type="checkbox"/> above final grade		
Depth from surface to normal water level <u>360</u> Ft.			Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>365</u> Ft.	Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>Oct 28</u> 19 <u>81</u>						
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.						
Signature <u>163 Donald C. Kirschbaum</u> Registered Well Driller				Business Name and Complete Mailing Address <u>Rt 4 Box 75</u> <u>Dons Well Drilling Rosabel Wis 53826</u>		