

AUG 8 1986

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION SE 1/4 SE 1/4 Section 34 Township 10N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Jim McDonald

OR - Grid or Street No. Street or Road Name ADDRESS R.R. 2 Box 30

AND - If available subdivision name, lot & block No. POST OFFICE Hayes Mills Wisc. ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) 25'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank	
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other				Seepage Pit	Seepage Bed	Seepage Trench	
				Clearwater Dr.	Clearwater Sump							<u>65'</u>		

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Private

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>81</u>			
<u>6</u>	<u>81</u>	<u>100</u>			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>loose sand</u>	<u>0</u> Surface	<u>78</u>
<u>sand rock</u>	<u>78</u>	<u>100</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>New Blacksteel</u> <u>Plain End</u> <u>KHC 18.97</u> <u>1.280 6x2W</u> <u>ASTM A 120 DR.</u>	<u>0</u> Surface	<u>81</u>

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 7-29 19 86

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Pitless Adaptor</u>	<u>0</u> Surface	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>81</u>

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 8 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 47 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 58 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to MADISON laboratory on 8-6 19 86

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael D. Reinbold Registered Well Driller

Business Name and Complete Mailing Address Corpsman Well Drilling
R.R. 2 Boscobel Wisc.