

NOV 7 8 1985

SEP 4 1985

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **Clayton**

2. LOCATION **SE 1/4, SE 1/4** Section **34** Township **10N** Range **4W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **Herb Geitz**

OR - Grid or Street No. Street or Road Name ADDRESS **R.R. 2**

AND - If available subdivision name, lot & block No. POST OFFICE **GAYS MILLS, WI.** ZIP CODE **54631**

4. Distance in feet from well to nearest: (Record answer in appropriate block) **10'**

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank
San.	Storm	C.I.	Other	Sewer		C.I.	Other				Seepage Pit	Seepage Bed	

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank

Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: **Private**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	0 Surface	84'			
6"	84	100'			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Loose Sand	0 Surface	65
gravel	65	82
Sandrock	82	100

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
6"	Plain End New Black Steel	0 Surface	84
	CA Conduven		
	A-53		
	.280W x # 18.97		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air Reverse Rotary

Rotary-w/drilling mud

Well construction completed on **8-22** 19 **85**

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	7 Surface	84
Pitless Adaptor	0	7

11. MISCELLANEOUS DATA

Yield Test: **2** Hrs. at **7** GPM Well is terminated **10** inches above final grade below

Depth from surface to normal water level **36** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **69** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON, WI.** laboratory on **8-27** 19 **85**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **1106 Mike Beinborn** Registered Well Driller

Business Name and Complete Mailing Address **CORPIAN WELL DRILLING INC. BOSCOBEL, WI. 53805**