

JAN 12 1981

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION SW 35 10N 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
OR - Grid or Street No. Street Name ADDRESS RFD Rays Mills
AND - If available subdivision name, lot & block No. POST OFFICE WV, 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block)

| | | | | | |
|----------|----------------------|----------------------|---------------------------|-------------------|-------------------|
| Building | Sanitary Bldg. Drain | Sanitary Bldg. Sewer | Floor Drain Connected To: | Storm Bldg. Drain | Storm Bldg. Sewer |
| C.I. | Other | C.I. | Other | C.I. | Other |
| C.I. | Other | C.I. | Other | C.I. | Other |

Street Sewer: San. Storm C.I. Other
Other Sewers: C.I. Other
Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump
Sewage Sump: C.I. Other
Clearwater Sump
Septic Tank
Holding Tank
Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

50'

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
|------------|------------|----------|------------|------------|----------|-----------------|------------|----------|
| 10 | Surface | 60 | 6 | 60 | 120 | Clay | Surface | 5 |
| | | | | | | soft shalestone | 5 | 45 |
| | | | | | | hard sandstone | 45 | 120 |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification & Method of Assembly | From (ft.) | To (ft.) |
|------------|--|------------|----------|
| 6 | new black steel P.E. 18.97 A-53 Kent Steels | Surface | 60 |
| | Hand pump | | |

8. GROUT OR OTHER SEALING MATERIAL

| Kind | From (ft.) | To (ft.) |
|--------|------------|----------|
| Clay | Surface | 2 |
| Cement | 2 | 60 |

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 12-23-1980

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 80 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 92 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 1-5-1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Zenneth Copian Registered Well Driller Complete Mail Address Boscobel, WV, R2 Box 4 53805

167