

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION E² 1/4 Section of Gov't. Lot Section 19 Township 10N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Fred Schrade

OR - Grid or Street No. Street or Road Name ADDRESS 2112-23rd St

AND - If available subdivision name, lot & block No. POST OFFICE Rockford Ill ZIP CODE 61101

4. Distance in feet from well to nearest: (Record answer in appropriate block) 15'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank		
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other	C.I.	Other	C.I.	Other	Seepage Pit	Seepage Bed	Seepage Trench		

60'

90'

Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard		Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit		Earthen Storage Trench Or Pit		Earthen Manure Basin	
		Well	Pump	Tank	Nonconforming Existing																		

Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)	
										Concrete Floor Only	Concrete Floor and Partial Concrete Walls		

5. Well is intended to supply water for: country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	75	6	75	100	clay shale	Surface	30
							30	100

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE 18.97 PSI 1200 A-120 Pitless adaptor	Surface	75

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
Cement	8	75

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM

Depth from surface to normal water level 60 Ft.

Depth of water level when pumping 64 Ft. Stabilized Yes No

Well construction completed on 5-13 1985

Well is terminated 12 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 5-15 1985

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller

Business Name and Complete Mailing Address Box 75
Dons Well Drilling Roswell WI 53805