

MAY 2 1985 OCT 8 1984

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **SEATELA SE FREEMAN**

2. LOCATION 1/4 Section **SE** Section **19** Township **T. 10N. 5W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **MICHAEL LARSON**

OR - Grid or Street No. Street Name ADDRESS **P.O. Box 42**

AND - If available subdivision name, lot & block No. POST OFFICE **MT. STERLING, WI.**

4. Distance in feet from well to nearest: (Record answer in appropriate block) **30'**

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump				Seepage Pit	Seepage Bed

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
-------	---------------	-----------------------------	---------------------	-------------	-----------------	-------------	---------------	------------------------------	--------------	--------------------------------------

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: **COUNTRY HOME**

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10"	0 Surface	61				DIRT - LOOSE ROCK	0 Surface	51
6"	61	140				SHALE	51	140

7. CASING, LINER, CURBING AND SCREEN			
Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6"	NEW BLACK STEEL PLAIN END	0 Surface	61
	A-53 18.97		
	CA. Conduven (D.T)		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
CEMENT	7 Surface	61
BURRY TANK	0	7

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on **9-26 1984**

11. MISCELLANEOUS DATA

Yield Test: **2** Hrs. at **5** GPM Well is terminated **10** inches above final grade below

Depth from surface to normal water level **80** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **80** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON** laboratory on **10-2 1984**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Kenneth Coplan** Registered Well Driller Complete Mail Address **CORPIAN WELL DRILLING, PO BOX 1, WI. 53805**