


**First Water Quality Test For
WISCONSIN UNIQUE WELL NUMBER AS 865**

AUG 4 1988 State of Wisconsin
Department of Natural Resources
Private Water Supply - WS/2
Box 7921
Madison, WI 53707

Property Owner: Dave Derksen Telephone Number: _____
Mailing Address: 5750 N 40 ST
City: Milwaukee State: WI Zip Code: 53209
County: Crawford County Well Location Permit No.: W Well Completion Date: 10/18/86

1. Location (Please type or print using a black pen.)
 Town City Village Fire # (if available) _____
of Freeman
Grid or Street Address or Road Name and Number (if available) _____

Well Constructor (Business Name): Don's Well Drilling 170 Registration # _____
Address: 16189 Dutch Hill Rd
City: Boscobel State: WI Zip Code: 53805



Subdivision Name _____ Lot # _____ Block # _____
Gov't Lot # _____ or SW 1/4 of NW 1/4 of Section 19; T 10 N; R 5 E W

3. Well Type New Replacement Reconstruction/Rehabilitation
of well constructed in 19 _____
Reason for new, reconstructed, replaced, or rehabilitated well?
 Drilled Driven Point Jetted Other _____

4. Well serves 1 # of homes and/or _____ (ex: barn, restaurant, church, school, industry, etc.)
High Capacity Well? Yes No
High Capacity Property? Yes No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? Yes No
Well Located in Floodplain? Yes No
Distance In Feet From Well To Nearest:
1. Landfill _____ 9. Downspout/Yard Hydrant _____ 17. Wastewater Sump _____
2. Building Overhang _____ 10. Privy _____ 18. Paved Animal Barn Pen _____
not in 3. Septic or Holding Tank _____ 11. Foundation Drain to Clearwater _____ 19. Animal Yard or Shelter _____
4. Sewage Absorption Unit _____ 12. Foundation Drain to Sewer _____ 20. Silo - Type _____
5. Nonconforming Pit _____ 13. Building Drain _____ 21. Barn Gutter _____
6. Buried Home Heating Oil Tank _____ 14. Building Sewer Gravity Pressure Cast Iron or Plastic Other _____ 22. Manure Pipe Gravity Pressure Cast Iron or Plastic Other _____
7. Buried Petroleum Tank _____ 15. Collector Sewer _____ 23. Other Manure Storage _____
8. Shoreline/Swimming Pool _____ 16. Clearwater Sump _____ 24. _____

6. Drillhole Dimensions

| Dia. (in.) | From (ft.) | To (ft.) |
|------------|------------|----------|
| 10 | surface | 66 |
| | | |
| | | |
| | | |

Method of constructing upper enlarged drillhole. (If applicable more than one.)
 1. Rotary - Mud Circulation
 2. Rotary - Air
 3. Rotary - Foam
 4. Reverse Rotary
 5. Cable-tool Bit _____ in. dia.
 6. Temp. Outer Casing _____ in. dia. Removed? Yes No
 If no, explain _____
 7. Other _____

9. Geology

| Type, Caving/Noncaving, Color, Hardness, Etc. | From (ft.) | To (ft.) |
|---|------------|----------|
| C- clay | surface | 8 |
| H- shale rock | 8 | 120 |
| N- sand rock | 120 | 160 |
| | | |
| | | |

7. Casing, Liner, Screen

| Dia. (in.) | Material, Weight, Specification Mfg. & Method of Assembly | From (ft.) | To (ft.) |
|------------|---|------------|----------|
| 6 | new Black Steel PE 18.97 | surface | 66 |
| | PSI 1200 | | |
| | A-120 | | |
| | USP | | |
| Dia. (in.) | screen type and material | From | To |

10. Static Water Level _____ ft. above ground level
112 ft. below ground surface
11. Pump Test
Pumping Level 111 ft. below surface
Pumping at 7 GPM for 3 hours
12. Well Is:
 Above Grade Below Grade
Developed? Yes No
Disinfected? Yes No
Capped? Yes No

8. Grout or Other Sealing Material

| Method | From (ft.) | To (ft.) | Sacks Cement |
|--------|------------|----------|--------------|
| clay | surface | 8 | |
| Cement | 8 | 66 | 22 |

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?
 Yes No If no, explain _____
14. Signature of Well Constructor: Donald C. Kirschbaum Date Signed: 8-2-88
Signature of Drill Rig Operator: Don Kirschbaum Date Signed: 8-2-88