

SEP 8 1980

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION 1/4 Section SW Section 21 Township 10 N Range 5 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name ??? ADDRESS Ralph Schlienz
RFD
 AND - If available subdivision name, lot & block No. POST OFFICE Ferrysville, WI, 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other
 Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 100' Seepage Pit Seepage Bed Seepage Trench
 Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
 Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS Kind From (ft.) To (ft.)
Clay Surface 0 20
hard shale stone 20 100

6. DRILLHOLE Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)
10 Surface 0 60 6 60 100

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly Dia. (in.) From (ft.) To (ft.)
new black steel 6 Surface 0 60
P.E. 18.97
A-53
Keystone Pipe
Pitless adapter

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)
Clay Surface 0 8
Cement 8 60

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water
 Rotary-air w/drilling mud Rotary-hammer & air
 Rotary-w/drilling mud Reverse Rotary

11. MISCELLANEOUS DATA Yield Test: 4 Hrs. at 5 GPM Well is terminated 8 inches above final grade below
 Depth from surface to normal water level 55 Ft. Well disinfected upon completion Yes No
 Depth of water level when pumping 62 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No
 Water sample sent to Madison laboratory on 9-3- 19 80

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boscobel, WI
181 R2 Box 4 53805