

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION NE of NE Section 9 Township 10N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 ADDRESS Janet Hopkins
2608 Williams Place

AND - If available subdivision name, lot & block No. Southcentral Pt POST OFFICE La Crosse ZIP CODE Wi 54601

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>60'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other
Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank
San. Storm	C.I. Other	Sewer Sewage Sump	C.I. Other	Clearwater Sump	Septic Tank
		Clearwater Dr. Sewage Sump			
Privy	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard
Pet Waste Pit	Well Pump Tank	Nonconforming Existing			
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin
					Concrete Floor Only Concrete Floor and Partial Concrete Walls

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>66</u>	<u>6</u>	<u>66</u>	<u>160</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel</u> <u>PE 18.97</u>	<u>0</u> Surface	<u>66</u>
	<u>A-53</u> <u>Valley Steel</u> <u>Pittler's adaptor</u>		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>15</u>
<u>loose rock</u>	<u>15</u>	<u>30</u>
<u>shale</u>	<u>30</u>	<u>110</u>
<u>sand rock</u>	<u>110</u>	<u>160</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>0</u> Surface	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>66</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 6-14-1982

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 120 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 122 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-15-1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Knochbaum Registered Well Driller Business Name and Complete Mailing Address RT4 Box 25
Dons Well Drilling Boocohel Wi 53805

191