


**First Water Quality Test For
WISCONSIN UNIQUE WELL NUMBER AZ 361**

SEP 23 1988 State of Wisconsin
Department of Natural Resources
Private Water Supply - WS/2
Box 7921
Madison, WI 53707

Property Owner Harold Dietsch Telephone Number 414 662-3002
Mailing Address 588 W 25860 Edgewood
City Mukwonago State Wi Zip Code 53199
County Crawford County Well Location Permit No. W Well Completion Date 09/10/88

1. Location (Please type or print using a black pen.)
 Town City Village Fire # (if available)
of Seneca
Grid or Street Address or Road Name and Number (if available)

Well Constructor (Business Name) Coyplan Well Drilling Registration # 75
Address 501 E. Oak
City Boscobel State Wi Zip Code 53805



Subdivision Name _____ Lot # _____ Block # _____
Gov't Lot # _____ or SW 1/4 of 35 1/4 of Section 35; T 10 N; R 6 E W

3. Well Type New
 Replacement Reconstruction/Rehabilitation
of well constructed in 19 _____

Reason for new, reconstructed, replaced, or rehabilitated well?
New Residence
 Drilled Driven Point Jetted Other _____

4. Well serves 1 # of homes and/or _____
(ex: barn, restaurant, church, school, industry, etc.)

High Capacity Well? Yes No
High Capacity Property? Yes No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? Yes No
Well Located in Floodplain? Yes No
Distance In Feet From Well To Nearest:
1. Landfill _____
20 2. Building Overhang _____
3. Septic or Holding Tank _____
4. Sewage Absorption Unit _____
5. Nonconforming Pit _____
6. Buried Home Heating Oil Tank _____
7. Buried Petroleum Tank _____
8. Shoreline/Swimming Pool _____

9. Downspout/Yard Hydrant _____
10. Privy _____
11. Foundation Drain to Clearwater _____
12. Foundation Drain to Sewer _____
13. Building Drain _____
 Cast Iron or Plastic Other _____
14. Building Sewer Gravity Pressure _____
 Cast Iron or Plastic Other _____
15. Collector Sewer _____
16. Clearwater Sump _____

17. Wastewater Sump _____
18. Paved Animal Barn Pen _____
19. Animal Yard or Shelter _____
20. Silo - Type _____
21. Barn Gutter _____
22. Manure Pipe Gravity Pressure _____
 Cast Iron or Plastic Other _____
23. Other Manure Storage _____
Other NR 112 Waste Source _____
24. _____

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
10	surface	42
6	42	65

Method of constructing upper enlarged drillhole. (If applicable more than one.)

1. Rotary - Mud Circulation
 2. Rotary - Air
 3. Rotary - Foam
 4. Reverse Rotary
 5. Cable-tool Bit _____ in. dia.
 6. Temp. Outer Casing 10 in. dia. Removed? Yes No
If no, explain _____
 7. Other _____

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
<u>MB Dirt & Loose Rock</u>	surface	16
<u>H- Shale</u>	16	32
<u>IN- White sandrock</u>	32	65

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	<u>New black Steel Plain End</u>	surface	42
	<u>ERW ASTM A-53 6x21 #18.97</u>		

10. Static Water Level _____ ft. above ground level
15 ft. below ground surface

11. Pump Test
Pumping Level _____ ft. below surface
Pumping at 5 GPM for 2 hours

12. Well Is:
14 in. Above Grade Below
Developed? Yes No
Disinfected? Yes No
Capped? Yes No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
<u>Tramee</u>	<u>Neat Cement</u>	surface	42	10

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?
 Yes No If no, explain _____

14. Signature of Well Constructor Michael D. Beinborn MDB Date Signed 9-19-88
Signature of Drill Rig Operator Michael D. Beinborn MDB Date Signed 9-19-88