

AUG 5 1983

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION SE of SW Section 36 Township 10N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Larry Weber

OR - Grid or Street No. Street or Road Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Delavan Wi ZIP CODE 53115

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pnuematic Tank
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other				Seepage Pit Seepage Bed Seepage Trench <u>65'</u>	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other: (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: house

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>0</u>	<u>90</u>	<u>6</u>	<u>90</u>	<u>120</u>	<u>clay</u>	<u>Surface</u>	<u>15-</u>
						<u>shale</u>	<u>15-</u>	<u>100</u>
						<u>sand rock</u>	<u>100</u>	<u>120</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel</u>	<u>PE 18.97</u>	<u>0</u>	<u>90</u>
		<u>1200 PSI</u>		
		<u>A-5-3</u>		
		<u>Valley Steel</u>		
		<u>Pattles adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>90</u>

Well construction completed on 6-8- 1983

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 90 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 92 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 7-6 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 202 Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address Don Well Drilling Box 75 Rt 4 Box 75 Boscobel WI 53805