


**First Water Quality Test For
WISCONSIN UNIQUE WELL NUMBER AZ 829**

State of Wisconsin
Department of Natural Resources
Private Water Supply - WS/2
Box 7921
Madison, WI 53707
JUN 30 1988

Property Owner Eugene Willison Telephone Number (608) 362-3194
Mailing Address 1256 Div. St.
City Bebit State Wi. Zip Code 53511
County Crawford County Well Location Permit No. W Well Completion Date 05/19/88
M M D D Y Y

1. Location (Please type or print using a black pen.)
 Town City Village Fire # (if available)
of Clayton
Grid or Street Address or Road Name and Number (if available)
Subdivision Name Lot # Block #

Well Constructor (Business Name) Coyplan Well Drilling Registration # 75
Address 501 E. Oak
City Boscobel State Wi. Zip Code 53805



Gov't Lot # 19 or NE 1/4 of SW 1/4 of Section 19; T 11 N; R 3 E W
3. Well Type New Replacement Reconstruction/Rehabilitation
of well constructed in 19
Reason for new, reconstructed, replaced, or rehabilitated well? New dwelling
 Drilled Driven Point Jetted Other

4. Well serves 1 # of homes and/or (ex: barn, restaurant, church, school, industry, etc.)
High Capacity Well? Yes No
High Capacity Property? Yes No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? Yes No
Well Located in Floodplain? Yes No 15 Distance In Feet From Well To Nearest:
1. Landfill 10
2. Building Overhang 89
2. Septic or Holding Tank
4. Sewage Absorption Unit
5. Nonconforming Pit
6. Buried Home Heating Oil Tank
7. Buried Petroleum Tank
8. Shoreline/Swimming Pool
9. Downspout/Yard Hydrant
10. Privy
11. Foundation Drain to Clearwater
12. Foundation Drain to Sewer
13. Building Drain Cast Iron or Plastic Other
14. Building Sewer Gravity Pressure Cast Iron or Plastic Other
15. Collector Sewer
16. Clearwater Sump
17. Wastewater Sump
18. Paved Animal Barn Pen
19. Animal Yard or Shelter
20. Silo - Type
21. Barn Gutter
22. Manure Pipe Gravity Pressure Cast Iron or Plastic Other
23. Other Manure Storage
Other NR 112 Waste Source
24.

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0 surface</u>	<u>50</u>
<u>6</u>	<u>50</u>	<u>80</u>

Method of constructing upper enlarged drillhole. (If applicable more than one.)
 1. Rotary - Mud Circulation
 2. Rotary - Air
 3. Rotary - Foam
 4. Reverse Rotary
 5. Cable-tool Bit 10 in. dia.
 6. Temp. Outer Casing 10 in. dia. Removed? Yes No
 If no, explain
 7. Other

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
<u>C</u> <u>Clay</u>	<u>surface</u>	<u>12</u>
<u>SG</u> <u>sand & gravel</u>	<u>12</u>	<u>26</u>
<u>SH</u> <u>soft shale</u>	<u>26</u>	<u>33</u>
<u>SG</u> <u>sand & gravel</u>	<u>33</u>	<u>45</u>
<u>IN</u> <u>White sandrock</u>	<u>45</u>	<u>80</u>

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>New black steel Plain End</u>	<u>surface</u>	<u>50</u>
	<u>CAC ASTM A-53 A</u>		
	<u>6 x 2 1/2 #18.97</u>		
Dia. (in.)	screen type and material	From	To

10. Static Water Level 18 ft. above ground level 18 ft. below ground surface
11. Pump Test
Pumping Level 33 ft. below surface
Pumping at 10 GPM for 2 hours
12. Well Is: 12 in. Above Grade Below Grade
Developed? Yes No
Disinfected? Yes No
Capped? Yes No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	Sacks Cement
<u>framed</u>	<u>Neat Cement</u>	<u>surface</u>	<u>50</u>	<u>22</u>

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant? Yes No If no, explain
14. Signature of Well Constructor Michael Beinborn MDR Date Signed 6/7/88
Signature of Drill Rig Operator Michael Beinborn MDR Date Signed 6/7/88