

NOV 1 1981
NOV 1 1981

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION NW of NE Section 33 Township 11N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Ruby Gray

OR - Grid or Street No. Street or Road Name ADDRESS Soldiers Grove WI 5-4655

AND - If available subdivision name, lot & block No. POST OFFICE ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 14'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Seepage Pit	Seepage Bed	Seepage Trench	Manure Hopper or Retention or Pneumatic Tank

55'

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Well	Pump	Tank	Subsurface Pumproom	Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
-------	---------------	-----------------------------	------	------	------	---------------------	------------------------	-------------	-----------------	-------------	---------------	------------------------------	--------------	--------------------------------------	----------------------

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Concrete Floor Only	Concrete Floor and Partial Concrete Walls	Other (Describe)
------------------------------------	--	----------------------	---------------------------------	---	----------------------	---------------------	---	------------------

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	105	6	105	380

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE 18.97	0	105
	A-53 Valley Steel Pitless adaptor		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
clay	0	10
lime rock	10	200
sand rock	200	280
shale rock	280	380

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	0	8
cement	8	105

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on Oct 30 1981

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 330 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 336 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Oct 28 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address Box 75
Don's Well Drilling Rosebud 53805

210