Well Construction Report For WISCONSIN UNIQUE WELL NUMBER AK633

State of Wisconsin
Department of Natural Resources
Private Water Supply — WS/2
Box 7921
Madison, WI 53707

JUN 21 1989

Property Owner: Wendt Rudolph — Telephone Number: 312 426-8256
Mailing Address: P.O. Box 9
City: Dundee — State: IL — Zip Code: 60118
County: 12 Crawford — County Well Location Permit No.: W — Well Completion Date: 6 08 89 (M M D D Y Y)

Well Constructor (Business Name): Corrigan Well Drilling — License #: 75
Address: 501 E. OAK
City: Boscobel — State: WI — Zip Code: 53805

1. Location (Please type or print using a black pen.)
☒ Town ☐ City ☐ Village of Wauzeka — Fire # (if available)
Grid or Street Address or Road Name and Number (if available)
Subdivision Name — Lot # — Block #
Gov't Lot # ____ or NE ¼ of SE ¼ of Section 15; T 7 N; R 5 ☐ E ☒ W

2. Mark well location in correct 40-acre parcel of section.
N / W / E / S

3. Well Type
☒ New ☐ Replacement ☐ Reconstruction/Rehabilitation
of well constructed in 19 ____.
Reason for new, reconstructed, replaced, or rehabilitated well? New Cabin
☒ Drilled ☐ Driven Point ☐ Jetted ☐ Other ____

4. Well serves 1 # of homes and/or — (ex: barn, restaurant, church, school, industry, etc.)

High Capacity Well? ☐ Yes ☒ No
High Capacity Property? ☐ Yes ☒ No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? ☒ Yes ☐ No
Well Located in Floodplain? ☐ Yes ☒ No
Distance In Feet From Well To Nearest:
- ____ 1. Landfill
- 90' 2. Building Overhang
- 125' 3. Septic or Holding Tank
- 170' 4. Sewage Absorption Unit
- ____ 5. Nonconforming Pit
- ____ 6. Buried Home Heating Oil Tank
- ____ 7. Buried Petroleum Tank
- ____ 8. Shoreline/Swimming Pool
- ____ 9. Downspout/Yard Hydrant
- ____ 10. Privy
- ____ 11. Foundation Drain to Clearwater
- ____ 12. Foundation Drain to Sewer
- ____ 13. Building Drain ☐ Cast Iron or Plastic ☐ Other
- ____ 14. Building Sewer ☐ Gravity ☐ Pressure ☐ Cast Iron or Plastic ☐ Other
- ____ 15. Collector Sewer
- ____ 16. Clearwater Sump
- ____ 17. Wastewater Sump
- ____ 18. Paved Animal Barn Pen
- ____ 19. Animal Yard or Shelter
- ____ 20. Silo — Type ____
- ____ 21. Barn Gutter
- ____ 22. Manure Pipe ☐ Gravity ☐ Pressure ☐ Cast Iron or Plastic ☐ Other
- ____ 23. Other Manure Storage ____
- Other NR 112 Waste Source
- ____ 24. ____

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
10	surface	148
6	148	340

Method of constructing upper enlarged drillhole. (If applicable ✓ more than one.)
- ☐ 1. Rotary — Mud Circulation
- ☒ 2. Rotary — Air
- ☐ 3. Rotary — Foam
- ☐ 4. Reverse Rotary
- ☐ 5. Cable-tool Bit ____ in. dia.
- ☒ 6. Temp. Outer Casing 10 in. dia. Removed? ☒ Yes ☐ No If no, explain ____
- ☐ 7. Other ____

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
6"	New Black Steel Plain End ERW ASTM A-53-A 6x21 #18.97	surface	148
Dia. (in.)	screen type and material	From	To

8. Grout or Other Sealing Material

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement	surface	148	47

9. Geology

	Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
-TC-	Dirt & clay	surface	19
-FL-	Lime rock & crevice	19	146
-L-	Lime rock	146	207
-U-	Sand rock	207	326
-H-	Shale	326	340

10. Static Water Level
258 ft. below ground surface

11. Pump Test
Pumping Level 280 ft. below surface
Pumping at 8 GPM for 2 hours

12. Well Is:
16 in. ☒ Above ☐ Below Grade
Developed? ☒ Yes ☐ No
Disinfected? ☒ Yes ☐ No
Capped? ☒ Yes ☐ No

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?
☐ Yes ☒ No If no, explain None

14. Signature of Well Constructor: Michael D. Beimborn MB — Date Signed: 6-19-89
Signature of Drill Rig Operator — Date Signed

Make additional comments on reverse side about geology, etc.

22

DNR WGNHS ORIGINAL

WELL CONSTRUCTION REPORT
Form 3300-77A Rev. 8-87