

Well Construction Report For
WISCONSIN UNIQUE WELL NUMBER AB354

State of Wisconsin
 Department of Natural Resources
 Private Water Supply - WS/2
 Box 7921
 Madison, WI 53707


Property Owner: Harry Lydlman Telephone Number: 319 266-2167
 Mailing Address: 2288 Parrieh St. (South) 50613
 City: Cedar Falls State: Iowa Zip Code: 50613
 County: Crawford County Well Location Permit No.: W Well Completion Date: 4-6-88
 M M D D Y Y

MAR 17 1992

1. Location (Please type or print using a black pen.)
 Town City Village Fire # (if available)
 of Freeman
 Grid or Street Address or Road Name and Number (if available)

Subdivision Name _____ Lot # _____ Block # _____
 Gov't Lot # _____ or SE 1/4 of SE 1/4 of SE
 Section 20; T 11 N; R 6 E W

Well Constructor (Business Name) License #
Don's Well Drilling 170
 Address: 16189 Dutch Hill Rd
 City: Boscobel State: WI Zip Code: 53805



3. Well Type New
 Replacement Reconstruction/Rehabilitation
 of well constructed in 19 88.

Reason for new, reconstructed, replaced, or rehabilitated well?
Didn't have a well
 Drilled Driven Point Jetted Other

4. Well serves 1 of homes and/or _____
 (ex: barn, restaurant, church, school, industry, etc.)
 High Capacity Well? Yes No
 High Capacity Property? Yes No

6. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? Yes No
 Well Located in Floodplain? Yes No
 Distance In Feet From Well To Nearest:
30' 1. Landfill
not 2. Building Overhang
see 3. Septic or Holding Tank
 4. Sewage Absorption Unit
 5. Nonconforming Pit
 6. Buried Home Heating Oil Tank
 7. Buried Petroleum Tank
 8. Shoreline/Swimming Pool
 9. Downspout/Yard Hydrant
 10. Privy
 11. Foundation Drain to Clearwater
 12. Foundation Drain to Sewer
 13. Building Drain
 Cast Iron or Plastic Other
 14. Building Sewer Gravity Pressure
 Cast Iron or Plastic Other
 15. Collector Sewer
 16. Clearwater Sump
 17. Wastewater Sump
 18. Paved Animal Barn Pen
 19. Animal Yard or Shelter
 20. Silo - Type _____
 21. Barn Gutter
 22. Manure Pipe Gravity Pressure
 Cast Iron or Plastic Other
 23. Other Manure Storage _____
 Other NR 112 Waste Source
septic no in

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
10	surface	288
6	288	360

Method of constructing upper enlarged drillhole. (If applicable - more than one.)
 1. Rotary - Mud Circulation
 2. Rotary - Air
 3. Rotary - Foam
 4. Reverse Rotary
 5. Cable-tool Bit _____ in. dia.
 6. Temp. Outer Casing _____ in. dia.
 Removed? Yes No
 If no, explain _____
 7. Other _____

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
↑ surface	↑	↑
clay	0	40
lime rock	40	220
sand rock	220	270
shale rock	270	360

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
4	new black steel PE 18.97	surface	288
	PSI-1200		
	A-120 1/2" sp		
Dia. (in.)	screen type and material	From	To

10. Static Water Level: 305 ft. below ground surface
 11. Pump Test: Pumping Level 307 ft. below surface
 Pumping at 8 GPM for 3 hours
 12. Well Is: 18 in. Above Grade Below Grade
 Developed? Yes No
 Disinfected? Yes No
 Capped? Yes No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	Sacks Cement
	clay	surface	8	
	cement	8	288	92

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?
 Yes No If no, explain no other well there
 14. Signature of Well Constructor: Don Kirschbaum DK Date Signed: 4-11-88
 Signature of Drill Rig Operator: Don Kirschbaum DK Date Signed: 4-11-88

222

WGNHS ORIGINAL