

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Freeman	
2. LOCATION OR - Grid or Street No. Street Name		1/2 Section SW Section 28 Township 11N Range 6W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Mary Balz	
AND - If available subdivision name, lot & block No.		ADDRESS RFD		POST OFFICE Ferryville, Wis; 54628	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 20'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump	
		Sewage Sump C.I. Other		Clearwater Sump	
		Septic Tank		Holding Tank	
		Sewage Absorption Unit 75'		Seepage Pit Seepage Bed Seepage Trench	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
		Barn Gutter		Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: Country home			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
10 Surface 0 88 6 88 160			Clay Surface 0 30		
			soft shalestone 30 70		
			hard shalestone 70 150		
			sandstone 150 160		
7. CASING, LINER, CURBING AND SCREEN			10. TYPE OF DRILLING MACHINE USED		
Material, Weight, Specification & Method of Assembly			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary		
Dia. (in.) From (ft.) To (ft.)			Well construction completed on 5 - 5 - 1980		
6 new black steel Surface 0 88			11. MISCELLANEOUS DATA		
P.E. 18.97			Yield Test: 3 Hrs. at 5 GPM		
A-53			Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Valley steel			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Pitless adapter			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
8. GROUT OR OTHER SEALING MATERIAL			Water sample sent to Madison laboratory on 5 - 8 - 1980		
Kind From (ft.) To (ft.)			Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.		
Clay Surface 0 8			Signature Kenneth Copian Registered Well Driller		
Cement 8 88			Complete Mail Address Boscobel, Wis R2 Box 4 53805		