

Note: - First log was for 72' - Redrilled to 92'

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH
See Instructions on Reverse Side

1. County Crawford Town Reckwood
 Village City Check one and give name
 2. Location 90'x90' - Smith addition - 1/2 mile N of H way 60
 Name of street and number of premise or Section, Town and Range numbers
 3. Owner or Agent Wood School Dist #2
 Name of individual, partnership or firm
 4. Mail Address Blue River, Wis. RFD #3
 Complete address required
 5. From well to nearest: Building 10 ft; sewer _____ ft; drain _____ ft; septic tank _____ ft;
 dry well or filter bed _____ ft; abandoned well _____ ft.

6. Well is intended to supply water for: School

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	0	6			
5"	6	92			

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
5"	Star Steel B.lk		
	pipe -	41 ft	used

9. GROUT:

Kind	From (ft.)	To (ft.)
Cement Grout	0	26

11. MISCELLANEOUS DATA:

Yield test: 11 Hrs. at 5 GPM.
 Depth from surface to water-level: 20 ft.
 Water-level when pumping: Same ft.
 Water sample was sent to the state laboratory at:
Last test
Madison on Sept 30 1956
 City Returns: Safe

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Sandy top soil	0	3
Heavy Dirt	3	26
Gravel Water etc	20	86
Sand Rock	86	92

RECEIVED

AUG 15 1957

ENVIRONMENTAL SANITATION

First drilled to 72' - Redrilled to 92'
 Construction of the well was completed on:

September 20 1956

The well is terminated 16' inches
 above, below the permanent ground surface.

Was the well disinfected upon completion?
 Yes Yes No _____

Was the well sealed watertight upon completion?
 Yes Yes No _____

Signature H. W. Bartels P.O. Box 175 - Bascohel, Wis
 Registered Well Driller Complete Mail Address

Please do not write in space below

Rec'd _____ No. _____
 Ans'd _____
 Interpretation _____

10 ml 10 ml 10 ml 10 ml 10 ml
 Gas—24 hrs. _____
 48 hrs. _____
 Confirm _____
 B. Coli _____
 Examiner _____